

Available online at [www.sciencedirect.com](http://www.sciencedirect.com)

ScienceDirect

journal homepage: [www.elsevier.com/locate/he](http://www.elsevier.com/locate/he)

CrossMark

## Evaluation of thermal comfort in a test room equipped with a photovoltaic assisted thermo-electric air duct cooling system

Kashif Irshad <sup>a,b,\*</sup>, Khairul Habib <sup>a,\*\*</sup>, M.W. Kareem <sup>a</sup>, Firdaus Basrawi <sup>c</sup>, Bidyut Baran Saha <sup>d,e</sup>

<sup>a</sup> Department of Mechanical Engineering, Universiti Teknologi PETRONAS, 32610, Bandar Seri Iskandar, Perak Darul Ridzuan, Malaysia

<sup>b</sup> Department of Mechanical Engineering, King Khalid University, P.O. Box 9004, Abha, 61413, Saudi Arabia

<sup>c</sup> Faculty of Mechanical Engineering, Universiti Malaysia Pahang, 26600, Pekan, Pahang, Malaysia

<sup>d</sup> International Institute for Carbon-Neutral Energy Research (WPI-I2CNER), Kyushu University, 744 Motooka, Nishi-ku, Fukuoka, 819-0395, Japan

<sup>e</sup> Mechanical Engineering Department, Kyushu University, 744 Motooka, Nishi-ku, Fukuoka, 819-0395, Japan

### ARTICLE INFO

#### Article history:

Received 22 February 2017

Received in revised form

21 April 2017

Accepted 26 May 2017

Available online 26 August 2017

#### Keywords:

Thermal comfort

Predicted mean vote (PMV)

Photovoltaic wall

Thermo-electric air duct

Hot-humid tropics

### ABSTRACT

This study investigates the comfort performance of a test room equipped with the south-facing photovoltaic wall (PV-W) and north-facing thermo-electric air duct (TE-AD) system for the tropical climate. Both subjective and objective measurements were used to analyze the TE-AD system cooling performance when operated at variable input current supply (2–7 A) from a PV system. Indoor radiant and air temperatures, relative humidity, and air velocity were measured based on ISO 7730 for objective measurement. For subjective measurement, forty respondents were required to fill up the questionnaire that developed based on UNI EN ISO 10551 and UNI EN ISO 7730 guidelines in order to access their thermal comfort opinion. The results show that the thermal response of respondents associated with indoor situation of the test room have changed from (+1) slightly warm to cool (–2) when the input current supply rises from 2 A to 6 A. The overall predicted mean vote, predicted percentage dissatisfied indices, and acceptability vote shows that more than 90% of the respondents were thermally satisfied. Integration of the PV-W system with the TE-AD system increases the thermal comfort and reduces the thermal load of the test room with other benefits includes less fuel and energy consumption, high reliability, and less maintenance operation.

© 2017 Hydrogen Energy Publications LLC. Published by Elsevier Ltd. All rights reserved.

\* Corresponding author. Department of Mechanical Engineering, Universiti Teknologi PETRONAS, 32610, Bandar Seri Iskandar, Perak Darul Ridzuan, Malaysia.

\*\* Corresponding author.

E-mail addresses: [alig.kashif@gmail.com](mailto:alig.kashif@gmail.com) (K. Irshad), [khairul.habib@utp.edu.my](mailto:khairul.habib@utp.edu.my) (K. Habib).

<http://dx.doi.org/10.1016/j.ijhydene.2017.05.247>

0360-3199/© 2017 Hydrogen Energy Publications LLC. Published by Elsevier Ltd. All rights reserved.